




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/School/WZ/2023/ 277

Dated:- 26/04/2023

FIRE SAFETY CERTIFICATE

Certified that the Vishal Bharti Public School Located at A-1, Block, Paschim Vihar, New Delhi- 110063 is running at Ground, 1st Floor & 2nd Floor only, in a building comprised of Ground + 03 Upper Floors only each owned/occupied by Modern Delhi Citizen Educational Society (Regd.) was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/01 dated 01.01.2020. The said premise was re-inspected by the officer concerned of this department on 31.03.2023 in the presence of Sh. Naresh Goyal (Caretaker) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Cr. No. 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 26/04/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below.

Issued on 26/04/2023.. at New Delhi by.


(Atul Gargi)
Director
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Vishal Bharti Public School, A-1, Block, Paschim Vihar, New Delhi-110063.

Following fire safety directives must be adhered to:-

1. This FSC is valid for Ground, 1st Floor & 2nd Floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
10. The School Principal has given an undertaking that we have sealed all entry levels of Third floor of our school building and we assure you that we shall not use third floor for any